EMERGENCY LIGHT/ EXIT LIGHT MONTHLY INSPECTION REPORT. ANNUAL SERVICE INSPECTIONS SHALL BEAR A SERVICE TAG BY A LICENSED CONTRACTOR.

IN ACCORDANCE TO THE 2019 CALIFORNIA FIRE CODE CHAPTER 10 SECTION 1031.10

1031.10 REQUIRED EMERGENCY LIGHTING SYSTEMS SHALL BE TESTED IN ACCORDANCE 1031.10-1031.10.2

1031.10.1 ACTIVATION TESTING OF REQUIRED EMERGENCY LIGHTING SYSTEMS SHALL BE PERMITTED TO BE CONDUCTED AS FOLLOWS:

1031.10.1 FUNCTIONAL TESTING SHALL BE CONDUCTED AT 30-DAY INTERVALS FOR NOT LESS THAN 30 SECONDS.

1031.10.2 POWER TEST FUNCTIONAL TESTING SHALL BE CONDUCTED ANNUALLY FOR NOTE LESS THAN 1 ½ HOURS IF THE EMERGENCY LIGHTING SYSTEM IS BATTERY POWERED.

THE EMERGENCY LIGHTING EQUIPMENT SHALL BE FULLY OPERATIONAL FOR THE DURATION OF THE TEST REQUIRED ABOVE.

108.3 WRITTEN RECORDS OF VISUAL INSPECTIONS AND TESTS SHALL BE KEPT BY THE OWNER FOR THE INSPECTION BY THE AUTHORITY HAVING JURISDICATION.

								1						
LOCATION	DATE	EXIT	EL	MAKE	MODEL	COLOR	BATTERY	30 SECOND	1 ½ HOUR TEST	PASS/FAIL	REPAIR	REPLACE	INTITAL	PO REPAIR
ADMIN	4/5/2013	Х		DUALLITE	LX	RED	EXAMPL	E x		PASS			JMM	
CAFTERIA	4/5/2013		Х	LED UNIT	120V	WHITE	AA Nicad		х	PASS			JMM	
ROOM 100		Х		DUALLITE	LX	RED	1.2V 1.1AH		Х	FAIL		Х		100345
LOCATION	DATE	EXIT	EL	MAKE	MODEL	COLOR	BATTERY	30 SECOND	1 ½ HOUR TEST	PASS/FAIL	REPAIR	REPLACE	INTITAL	PO REPAIR

EMERGENCY LIGHT/ EXIT LIGHT MONTHLY INSPECTION REPORT. ANNUAL SERVICE INSPECTIONS SHALL BEAR A SERVICE TAG BY A LICENSED CONTRACTOR.

LOCATION	DATE	EXIT	EL	MAKE	MODEL	COLOR	BATTERY	30 SECOND	1 ½ HOUR TEST	PASS/FAIL	REPAIR	REPLACE	INTITAL	PO REPAIR
			_			_			_		_			