



# Alpine Fire Protection District

1364 TAVERN RD. ALPINE, CA 91901-3831  
 BUSINESS (619)445-2635 • FAX (619)445-2634

## Monthly Inspection and Record of Large Family Day-Care R-3 Occupancy.

In accordance with the California Fire Code 2019 edition Chapter 9 Section 907.2.6.4

*907.2.6.4 Large family day care. Every large family day-care home shall be provided with at least one manual device at a location approved by the enforcing agency. Such device shall actuate a fire alarm signal,*

*which shall be audible throughout the facility at a minimum level of 15 db above ambient noise level. These devices need not be interconnected to any other fire alarm device, have a control panel or be electrically supervised or provided with emergency power. Such device or devices shall be attached to the structure and may be of any type acceptable to the enforcing agency, provided that such devices are distinctive in tone and are audible throughout the structure.*

The required monthly service of the manual alarm device shall be completed and recorded below for reference. This is to ensure operation of the devices and safety equipment. Your semi-annual evacuation drills may be at your choosing.

Should any correction be noted please make contact with a service repair company immediately to ensure that no lapse of service is present. If you have any questions or would like further detailed instructions please feel free to contact the Fire Marshal. 619-445-2635 x 308

Month	Location Tested	Audible Alarms	Visual Alarms	System Reset	Date Tested	Time Tested	Restore Complete	Corrections
January								
February								
March								
April								
May								
June								
July								
August								
September								
October								
November								
December								

Contact your fire alarm vendor to place system in test mode prior to any testing. Please also notify local fire department prior when testing is to be completed. Any issues alarms not resettable please contact your fire alarm vendor immediately do not disconnect any devices.